



CFA GmbH
Fachbereich Pharma-, Material- & Umweltanalytik

Certificate

for conducted tests and research

Tested products:
Getestete Produkte:

Steel grid / cable mesh

Manufacturer/Distributor:
Hersteller/Händler:

Carl Stahl ARC GmbH

Type of product:

**X-TEND CXL100/30, mesh size 100mm at 60°,
Ø 3,0mm**

Produkttyp:

Number of certificate:
Zertifikatnummer:

14062024-034

Number of Cfa report:
Cfa-Bericht-Nummer:

Cfa2024-3038

Test program:
Testprogramm:

DIN EN ISO 1627:2011

Test results:
Untersuchungsergebnisse:

RCIII (5min): **passed**

Damaged mesh diamonds : 2

Damaged area: 120 [in cm²]

Resistance time/mesh: 150 [in s]

Extrapol. access time: 875 [in s]

Validity of certificate:
Gültigkeit des Zertifikats bis:

June 2027

CFA GmbH
Fachbereich Pharma-, Material- & Umweltanalytik
Rechberghäuser Weg 11
D73035 Göppingen
Germany

Göppingen, 16.06.2024

Lab director: Dipl.-Biol. Marc Hradecky