



CFA GmbH
Fachbereich Pharma-, Material- & Umweltanalytik

Certificate

for conducted tests and research

Tested products:
Getestete Produkte:

Steel grid / cable mesh

Manufacturer/Distributor:
Hersteller/Händler:

Carl Stahl ARC GmbH

Type of product:

**X-TEND CXL70/20, mesh size 70mm at 60°,
Ø 2,0mm**

Produkttyp:

Number of certificate:
Zertifikatnummer:

08072024-037

Number of Cfa report:
Cfa-Bericht-Nummer:

Cfa2024-3151

Test program:
Testprogramm:

DIN EN ISO 1627:2011

Test results:
Untersuchungsergebnisse:

RCIII (5min): **passed**

Damaged mesh diamonds : 10

Damaged area: 78 [in cm²]

Resistance time/mesh: 30 [in s]

Extrapol. access time: 1346 [in s]

Validity of certificate:
Gültigkeit des Zertifikats bis:

July 2027

CFA GmbH
Fachbereich Pharma-, Material- & Umweltanalytik
Rechberghäuser Weg 11
D73035 Göppingen
Germany

Göppingen, 08.07.2024

Lab director: Dipl.-Biol. Marc Hradecky